



**NEW MEXICO  
ENVIRONMENT DEPARTMENT**



SUSANA MARTINEZ  
Governor  
JOHN A. SANCHEZ  
Lieutenant Governor

P.O. Box 5469  
Santa Fe, NM 87502-5469  
Phone (505) 476-8620 Fax (505) 476-8656  
[www.env.nm.gov](http://www.env.nm.gov)

RYAN FLYNN  
Cabinet Secretary  
BUTCH TONGATE  
Deputy Secretary

**CERTIFIED RETURN RECEIPT REQUESTED  
7005 1820 0001 5772 3576**

September 11, 2015

Frank R. Madrid  
Lordsburg Water Supply System  
409 W. Wabash Street  
Lordsburg, NM 88045

**RE: Settlement Agreement and Stipulated Final Order, No. 2013-ACO-006 Lordsburg  
Water Supply System, PWS# NM3522812  
Request for Extension**

Mr. Madrid:

The New Mexico Environment Department (NMED) Drinking Water Bureau received your request for extension letter dated August 26, 2015. The NMED has reviewed your request and agrees to modify Paragraph 9 of Settlement Agreement and Stipulated Final Order No. 2013-ACO-006. Paragraph 9 shall be modified to read "By December 31, 2015, Respondent must have a RAA for Fluoride below 4.0 mg/L, and be in compliance with Section 20.7.10.100 NMAC, incorporating 40 C.F.R. § 141.23(i)(1)."

If you have any questions or need assistance, please contact Maria J. Medina, Enforcement Coordinator, at 505-476-8629 or via email at [maria.medina@state.nm.us](mailto:maria.medina@state.nm.us).

Sincerely,

Trais Kliphuis  
Division Director  
Water Protection Division

cc. Ray Melendrez, Compliance Officer  
Jenna Manheimer, Region 6, EPA (Electronic)  
P:\-ENFORCEMENT\Individual PWS Enforcement Info  
Central File

## CERTIFICATE OF SERVICE

I hereby certify that a copy of the foregoing letter was sent via certified return receipt requested on the following party of record on 5/11, 2015.

Frank R. Madrid  
Lordsburg Water Supply System  
409 W. Wabash Street  
Lordsburg, NM 88045



---

Maria J. Medina